

	95°F(35.0℃)	PI	2.66	2.66	2.67	2.67	2.67	2.82	2.82	2.83	2.83	2.83	2.99	2.99	3.00	3.00	3.00	3.17	3.17	3.18	3.18	3.18
		TC	34889	34936	34973	34975	35022	36991	37035	37072	37079	37123	39201	39252	39296	39303	39347	41563	41608	41654	41660	41712
		S/T	0.53	0.63	0.71	0.71	0.81	0.57	0.66	0.75	0.75	0.86	0.60	0.70	0.80	0.80	0.91	0.64	0.75	0.85	0.85	0.97
	104°F(40.0℃)	PI	3.40	3.40	3.41	3.41	3.41	3.60	3.61	3.61	3.61	3.62	3.82	3.82	3.83	3.83	3.83	4.05	4.05	4.06	4.06	4.06
		TC	32070	32113	32147	32149	32192	34002	34043	34076	34083	34123	36034	36080	36121	36127	36168	38205	38246	38288	38294	38342
		S/T	0.55	0.64	0.73	0.73	0.83	0.58	0.68	0.77	0.77	0.88	0.62	0.72	0.82	0.82	0.93	0.65	0.76	0.87	0.87	0.99
	110°F(43.0℃)	PI	3.69	3.69	3.70	3.70	3.70	3.91	3.92	3.92	3.92	3.92	4.14	4.15	4.15	4.16	4.16	4.39	4.40	4.40	4.40	4.41
		TC	30378	30419	30452	30453	30494	32209	32247	32279	32285	32324	34133	34177	34216	34222	34260	36190	36229	36268	36274	36319
		S/T	0.57	0.67	0.76	0.76	0.86	0.60	0.71	0.80	0.80	0.91	0.64	0.75	0.85	0.85	0.97	0.68	0.79	0.90	0.90	1.00
	115°F(46.0℃)	PI	3.86	3.87	3.87	3.87	3.88	4.09	4.10	4.10	4.10	4.11	4.34	4.35	4.35	4.35	4.36	4.60	4.61	4.61	4.61	4.62
		TC	23213	23244	23269	23270	23302	24612	24641	24665	24670	24699	26082	26116	26145	26150	26179	27654	27684	27714	27718	27753
		S/T	0.57	0.67	0.77	0.77	0.87	0.61	0.71	0.81	0.81	0.92	0.65	0.76	0.86	0.86	0.98	0.68	0.80	0.91	0.91	1.00
	122°F(50.0℃)	PI	3.11	3.12	3.12	3.12	3.12	3.30	3.30	3.31	3.31	3.31	3.50	3.50	3.50	3.51	3.51	3.71	3.71	3.72	3.72	3.72
		TC	13659	13678	13692	13693	13711	14482	14500	14514	14517	14534	15348	15368	15385	15388	15405	16272	16290	16308	16310	16331
		S/T	0.59	0.69	0.78	0.78	0.89	0.62	0.73	0.83	0.83	0.95	0.66	0.77	0.88	0.88	1.00	0.70	0.82	0.93	0.93	1.00
		PI	2.11	2.11	2.12	2.12	2.12	2.24	2.24	2.24	2.24	2.25	2.37	2.38	2.38	2.38	2.38	2.52	2.52	2.52	2.52	2.52

TC:Total Cooling Capacity (BTU/hr)

S/T:Sensible Cooling Capacity Ratio

PI:Power Input(kW)

Extrapolatred Data

The data highlighted in green are tested, other data are simulated and for reference only